

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1483:152

Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410  
Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

**DESIGN:** Models MC20FTU-3 and MC20RRU-3 two-wire heat detectors. Model MC20FTU-3 is a 135°F fixed temperature detector and Model MC20RRU-3 is a 135°F fixed temperature and a 15°F/min rate of rise detector. Refer to listee's data sheet for detailed model descriptions and operational considerations.

**RATING:** 10-30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Model number, electrical rating, UL label and one of the following: Listee's name, or Edwards System Technology (EST).

**APPROVAL:** Listed as 2-wire heat detectors for use with listee's separately listed compatible bases and fire alarm control units.

**XLF:** 7270-1388:242

08-29-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**